## PIFSC INSPECTION CHECKLIST

The following checklist is a guide. It may be used in its entirety or be modified to the specific user's needs by adding or subtracting items from the checklist. For questions concerning any item, contact the PIFSC SECO.

## FLOOR & WALL OPENINGS

Name:		Date:	
Location of Inspection:			
1. Are floor openings guarded by a cover, guardrail, or equivalent on all sides (except at entrance to stairways or ladders)?	Yes 🗆 No 🗀	Comments:	
2. Are toeboards installed around the edges of a permanent floor opening (where persons may pass below the opening)?	Yes 🗆 No 🗆	Comments:	
3. Are skylight screens of such construction and mounting that they will withstand a load of at least 200 pounds?	Yes 🗆 No 🗆	Comments:	
4. Is the glass in windows, doors, glass walls that are subject to human impact, of sufficient thickness and type for the condition of use?	Yes 🗆 No 🗆	Comments:	
5. Are grates or similar type covers over floor openings such as floor drains, of such design that foot traffic or rolling equipment will not be affected by the grate spacing?	Yes 🗆 No 🗀	Comments:	
6. Are unused portions of service pits and pits not actually in use either covered or protected by guardrails or equivalent?	Yes 🗆 No 🗆	Comments:	

cover their a tru 20,00	manhole covers, trench es and similar covers, plus supports, designed to carry ck rear axle load of at least 0 pounds when located in ways and subject to vehicle c?	Yes □ No □	Comments:
resist with with struc closir	loor or wall openings in fire ive construction provided doors or covers compatible the fire rating of the ture and provided with selfing feature when opriate?	Yes 🗆 No 🗆	Comments: